



# GERAND ENGINEERING

141 CHESHIRE LANE N, SUITE 100, MINNEAPOLIS MN 55441  
952.374.1320 WWW.GERAND.COM

## FIRE PUMP TEST METER G-3500-10


### CONSTRUCTION & SPECIFICATIONS

- VENTURI: ZINC PLATED STEEL
- VALVES: ONE PIECE BRASS BODY  
ZINC DIECAST STEEL HANDLE
- ID TAG: Chain: brass  
Tag: Aluminum
- HOSES: GOODYEAR 3/6" FREON CHARGE  
HOSES WITH NYTRILE CORE,  
POLYESTER BRAID AND NYTRILE  
COVER WITH PVC FOR ABRASION  
RESISTANCE

### METER DATA

- CONSTRUCTION: ALUMINUM BODY
- OPERATION: BUNA "N" DIAPHRAGM
- ACCURACY: ±2.0%
- TEMPERATURE: 200° F MAX
- PRESSURE: 1500 PSI MAX
- APPROX. WEIGHT: 3 LBS/EACH

4 1/2" DIAL STANDARD - 6" AVAILABLE



### WEIGHTS & DIMENSIONS

- WEIGHT: 37 LBS
- SHIPPING DIMENSIONS: 16" x 16" x 16" BOX